



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

January 6, 2010

Stephen Renner  
Franklin County  
280 East Broad Street  
Columbus, OH 43215

**Re: Storm Water Inspection Cleveland Heights Phase 3 Sanitary Improvements  
Permit Number: 4GC03124\*AG**

Dear Mr. Renner:

This letter is written in follow-up to a construction storm water inspection I conducted at Cleveland Heights Phase 3 Sanitary Improvements located near the intersection of Abington and Sharon Road in Franklin County on December 30, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

- All remaining barren areas must be temporarily stabilized in preparation for the remaining winter months within seven days from receipt of this letter. Given the time of the month, a crimped mulch cover is expected.
- I noted two large stockpiles which appeared to be excess material associated with this project (see attached photos). Corrective measures are expected to ensure these stockpiles are protected from erosion with a crimped mulch cover and surrounded by silt fence or equivalent. The General Permit requires the stabilization of all waste and borrow areas associated with this project as they are specifically addressed in the permit requirements.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).


Sincerely

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

HK/hsm Cleveland Heights 12-30-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director





**Figure 1 and 2: Stockpiles must be protected from erosion with a crimped mulch cover and surrounded by silt fence**

