



State of Ohio Environmental Protection Agency

RECEIPT ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

January 6, 2010

Jack Berry
Midwest Church Design
634 Eckel Road
Perrysburg, OH 43551

**Re: Storm Water Inspection Jesus Power Assembly of God
Permit Number: 4GC02977*AG**

Dear Mr. Berry:

This letter is written in follow-up to a construction storm water inspection I conducted at Jesus Power Assembly of God located in Franklin County on December 30, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The majority of the site is developed and currently draining to a large impoundment located on the eastern end of the building
- All remaining barren areas must be temporally stabilized in preparation for the remaining winter months.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
[Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Jack Berry
Midwest Church Design
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office.