



State of Ohio Environmental Protection Agency

PHYSICAL ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 29, 2009

David White
Site Solutions Contractors
38 East Columbus Street
Pickerington, OH 43147

Re: Site Solutions Corporate Office / Fairfield County

Dear Mr. White:

This letter is written regarding the storm water inspection I conducted on December 23, 2009, of the construction activities at the Site Solutions Corporate Office located in the southwestern corner of Pickerington Road and US 33, in Pickerington, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

As stated previously, the sediment basin has a lot of vegetation, i.e., cattails. The vegetation must be removed from the sediment basin.

Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days or areas that are at final grade be protected from erosion (i.e., seed and straw), within seven days from the last construction activity. In addition, erosion protection must be implemented for all areas of final grade within seven days. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the winter months.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

David White
Site Solutions Contractors
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO