OhioEPA

State of Ohio Environmental Protection Agency

STREET ADDRESS: **Central District Office** MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

December 29, 2009

Jim Johnson
Storage One, LLC
P.O. Box 145
Carroll, OH 43112

Re: Storage One, LLC / Franklin County

Dear Mr. Johnson:

This letter is written regarding the storm water inspection I conducted on December 24, 2009, of the construction activities at Storage One, LLC located at 4975 Gender Road, in Columbus, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GLS/nsm Storage One, LLC, December 24, 2009