



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 200  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

December 29, 2009

Scott Earhart  
P.O. Box 39  
Troy, OH 45373

**Re: Storm Water Inspection at Earhart Petroleum Inc in Reynoldsburg, Ohio  
Permit Number 4GR00346\*DG**

Dear Mr. Earhart:

This letter is written in follow-up to a construction storm water inspection I conducted at Earhart Petroleum located Reynoldsburg, Ohio on December 14, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Industrial Activities. During the inspection, I noted the following:

Please forward to my attention the Storm Water Pollution Prevention Plan (SWPPP) and Spill Control and Countermeasure (SPCC) plan for review

The earthen embankment associated with the large storage tanks should be replaced with concrete structures.

The containment pad utilized for loading and unloading was full of storm water. This Best Management Practice (BMP) should be better managed to ensure containment capacity in the event of a spill during the loading/unloading process.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to this letter within seven days of receipt.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Earhart Petroleum 12-14-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

