



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 29, 2009

James Sisto
Central Ohio Community Improvement Corporation
919 Old Henderson Road
Columbus, OH 43220

Re: Storm Water Inspection Bedford Landfill Permit Number 4GC02548*AG

Dear Mr. Sisto:

This letter is written in follow-up to a construction storm water inspection I conducted at Bedford Landfill located in Gahanna, Ohio on December 14, 2009. The purpose of the inspection was to evaluate your compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The site is currently subject to stabilization through seeding and mulching efforts. Please continue with these efforts to ensure all barren areas are adequately protected in preparation for the winter months.
- The site must be inspected and every seven days and within 24 hours of a precipitation event equal to or greater than 0.5 inches. All deficiencies must be logged and repaired in accordance with General Permit conditions. Generally deficiencies must be corrected within three days of discovery. The inspection logs must be maintained onsite available for review.

Post Construction:

- It was my understanding the post construction management practices were revised to address the concerns associated with the centralized basin with respect to adequate water quality volume storage. Please indicate in your response letters which alternatives were chosen.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortleski, Director

James Sisto
Central Ohio Community Improvement Corporation
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. Please provide a written response to this letter within seven days.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Ted Hunker, Tartan Golf & Management

HK/nsm Bedford Landfill 12-14-09