



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

December 17, 2009

Charles Driscoll
Nelson Farms Associates, LLC
495 South High Street
Columbus, OH 43215

Re: Construction Storm Water Inspection at Nelson Farms Subdivision

Dear Mr. Driscoll:

This letter is written regarding the storm water inspection I conducted at Nelson Farms Subdivision located North of Home Road and State Route 315 in Delaware County on December 9, 2009. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Significant barren areas have been protected as previously request in preparation for the upcoming months. Please continue to monitor the areas to ensure effective erosion control.
- Self inspection must continue at a frequency of every seven days and within 24 hours of a precipitation event equal to or greater than 0.5 inches. Logs of the inspection must be available upon request.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

HK/nsm Nelson Farms 12-9-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

