



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 17, 2009

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit #4GC03083*AG, December 8, 2009**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on December 8, 2009. On this date I met with with Igel construction regarding winter stabilization. During the inspection, the following items were evaluated:

Sediment and Erosion Controls:

- The site has been recently protected with erosion with a straw mulch cover, specifically the south central portion of the site. Please continue to implement erosion control measures to ensure all barren areas are adequately protected for the upcoming winter months.
- At this time, I am formally requesting additional information regarding the final discharge point to waters of the state associated with the southwestern impoundment. The Storm Water Pollution Prevention Plan (SWPPP) was unclear regarding the point of discharge to waters of the state.

Permitting Requirements:

- I spoke with your consultant regarding the four stream crossings within a linear mile associated with this site. It appears the crossings are authorized under Nationwide Permti 39 according to your consultant. I have requested a copy of the Pre-Construction Notification to close the issue.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ron Strussion
Reynoldsburg City Schools
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Kevin Ballog, Smoot Construction

HK/nsm Summit Road High School, 12/08/09



Figure 1: Depicting Improvement Opportunities with respect to Fluid Management



Figure 2: Noted Debris in Yard from log storage and De-barking

