



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 12, 2010

Teresa Hummell
Cardington Yutaka Technologies, Inc.
575 West Main Street
Cardington, OH 43315

Re: Village of Cardington / Morrow County
Non-contact cooling water

4GR00276 #DG

Dear Ms. Hummell:

It has come to my attention that the sewer use ordinance for the Village of Cardington prohibits the discharge of non-contact cooling water (NCCW) and "polluted non-contact cooling water." Also, the NCCW has an elevated pH that does not meet the sewer use ordinance for a discharge to the Village of Cardington's sanitary sewer system. The sewer use ordinance only allows discharges between a pH of 5 and 9 s.u. The pH of your NCCW appears to be greater than 9.0 s.u. As such, Cardington Yutaka Technologies, Inc. must cease discharging NCCW to the Village of Cardington's sanitary sewer system and find an alternative disposal method for their NCCW. You may apply for an individual National Pollutant Discharge Elimination System permit to discharge the NCCW to waters of the state. You must first submit and obtain the individual discharge permit from the Ohio Environmental Agency. The NCCW from your facility would not be eligible to apply for a general permit for the NCCW.

If you have any questions or comments regarding this correspondence, please call me at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne CDO/DSW
Fred Razavi, Cardington Yutaka Technologies, Inc.
Tom Reynolds, Village Administrator, Village of Cardington

GLS/nsm 9November2010NCCW_CYT

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



