



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3772 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 15, 2009

Craig Van Bremen
Berry & Miller Construction
42 Hill Road South
Pickerington, OH 43147

Re: Storm Water Inspection at Strike City

Dear Mr. Van Bremen:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Sean Tyler, of the Ohio EPA, at Strike City located at Windmill Drive, South of Old Diley Road in Pickering Ohio on June 23, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Upon inspection, current perimeter silt fence along the site have failed and will require repair. In particular, silt fence along the back side of the site has failed resulting in sediment run-off exiting the construction site (See Figure 1).
- In addition, it was noted that a concrete wash-out area has not been established on the site and was being washed directly onto a slope at the rear side of the site with failed silt fences located directly below the wash area (See Figure 2). A concrete wash out area must be established which contains all wash water
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Craig Van Bremen
Berry & Miller Construction
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Strike city June 23, 2009



Figure 1.




Figure 2.

