



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3998
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Kenneth L. Koppes
Edinburgh Cove LTD
1038 Edinburg Cove
London, OH 43140

Re: Edinburgh Cove III/Permit #4GC02371*AG

Dear Mr. Koppes:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at Edinburgh Cove III located at the end of Wesley Drive in Madison County on July 9, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The construction entrance requires stabilization to minimize off-site vehicle tracking.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This specifically applies to the dirt piles on site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Edinburgh Cove III July 9, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

