



State of Ohio Envir

Northeast



\* 0 H 0 4 0 0 5 1 2 4 2 7 9 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Gov. Ed. Whitaker, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

May 11, 2010

RE: ASHTABULA COUNTY  
DFC MOBILE HOME PARK  
PWS TYPE: COMMUNITY  
PWS ID: OH0400512

Ms. Lois Adkins  
1600 Lenox-New Lyme Road  
Jefferson, OH 44047

**Subject: Failure to Sample Source Water for Fecal Indicators (Total Coliform) as Required**

Dear Ms. Adkins:

DFC Mobile Home Park is in violation of Federal Code, Rule 141.402 for failure to comply with the Ground Water Rule monitoring.

<b>Monitoring Period:</b>	May 2010
<b>Required Monitoring:</b>	1 per Month
<b>Sample Results Submitted:</b>	0

**ACTION REQUIRED:**

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

**Timing:** As soon as practical, but no later than one year after learning of the violation:


- Mail or other direct delivery to each customer; OR
- Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and
- If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting or Internet posting;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

**2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

If source water (raw) samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1199.

Sincerely,



Stephen Bopple, P.E.  
Environmental Engineer  
Division of Drinking and Ground Waters

SB:ds

enclosures: Tier 3 Public Notification  
Public Notice Instructions & Verification Form

cc: Ashtabula County Health Department  
Information Management Section, DDAGW, CO  
Kim Etters, DDAGW, NEDO