



NOTICE OF VIOLATION – ACTION REQUIRED

July 14, 2010

**RE: CARROLL COUNTY
DELLROY DRIVE-IN RESTAURANT
NON-COMMUNITY, TRANSIENT
PWS ID: OH1036212**

Ms. Angela Townsend
387 Avalon Road
Dellroy, OH 44620

**Subject: Failure to Conduct Required Repeat Total Coliform and
Ground Water Rule Monitoring**

Dear Ms. Townsend:

Dellroy Drive-In Restaurant is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), and the Ground Water Monitoring Rule 3745-81-21 Federal Regulation 40CFR141.402 for April-June 2010.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 6/28/2010 and the required repeat samples were not collected. For your water system the four repeat samples also satisfy the Ground Water Rule requirement for the initial raw water sample. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

IMMEDIATE ACTION REQUIRED:

1. **Consult with Ohio EPA within 24 hours** regarding sampling and public notice requirements. If you have not already received direction regarding this violation, contact the NEDO at 330-963-1293.
2. **Issue the enclosed public notices within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system;
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Send to parents or guardians of children at schools or day care facilities;
 - Another delivery method approved in writing by the director;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.

DELLROY DRIVE-IN RESTAURANT

JULY 14, 2010

PAGE 2

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notices** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.

Attention: As noted above, your repeat samples are also used to address your Federal Ground Water Rule violation. Failure to collect the raw water sample may result in enforcement action by the United States Environmental Protection Agency (USEPA). Ohio EPA must receive these results to return the system to compliance and prevent referring this violation to the USEPA.

5. **Monitor with at least five (5) routine samples** in the month following (July 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact Cynthia M. Petretich at 330-963-1293.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures: Tier 1 Public Notification
Tier 3 Public Notification
Public Notice Instructions and Verification Form

cc: Carroll County Health Department
Information Management Section, DDAGW, CO
Cynthia M. Petretich, DDAGW, NEDO
Kim Etters, DDAGW, NEDO