

**Environmental
Protection Agency**

Gov. Ed. Brown, Governor
Lieb. Fisher, Lt. Governor
Chris Karpisich, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

November 2, 2010

RE: COLUMBIANA COUNTY
WESTVILLE LAKE CAMPGROUND BATHHOUSE
NON-COMMUNITY, TRANSIENT
PWS ID # OH1533622

Mr. Mike Dreger
1010 N. Walnut Ave.
Alliance, OH 44601

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2010**

Westville Lake Campground-Bathhouse is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

As stated in a letter sent October 19, 2010, a routine sample was collected from your facility on 10/4/2010 and determined total coliform positive. OAC Rule 3745-81-21 requires four repeat samples to be collected in a timely fashion and on the same day upon notification of the positive routine sample result(s). Westville Lake Campground Bathhouse did not collect the four required repeat samples and therefore are in violation of the OAC. A public notice water use advisory was required to be issued because of this violation. The public notice for the water use advisory must remain in effect until you obtain one complete set of four repeat samples that are determined total coliform negative.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;

WESTVILLE LAKE CAMPGROUND-BATHHOUSE
NOVEMBER 2, 2010
PAGE 2

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
 4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued. According to our records, Westville Lake Campground Bathhouse is closed for the season. Therefore, collect the four (4) repeat samples in May 2011 when you reopen. Because your water system does not have treatment, the four repeat samples would also satisfy the Ground Water Rule requirement for the initial raw water sample. Your water system will remain on a Water Use Advisory until four (4) negative repeat samples are collected.
 5. **Monitor with at least five (5) routine samples** in the month following (November 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). According to our records, Westville Lake Campground Bathhouse is closed for the season. Therefore, collect the five (5) routine samples in May 2011 when you reopen.

If you have any questions, contact this office at 330-963-1293.

Sincerely,



Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Columbiana County Health Department
Information Management Section, DDAGW, CO
Kim Etters, DDAGW, NEDO