

  
**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korfeski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

July 16, 2010

**RE: GEAUGA COUNTY  
ST HELENS SCHOOL  
NON-TRANSIENT NON-COMMUNITY  
PWS ID: OH2838412**

Mr. Ken Moses  
12060 Kinsman Road  
Newbury, OH 44065

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During July 2010**

Dear Mr. Moses:

St Helens School is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - NEDO.** Include a copy of each notice distributed, published or posted.

ST HELENS SCHOOL  
JULY 16, 2010  
PAGE 2

**4. Monitor with at least five (5) routine samples** in the month following (August 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1182.

Sincerely,



Laurel Hricik  
Environmental Specialist  
Division of Drinking and Ground Waters

LH:ds

enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Geauga County Health Department  
Information Management Section, DDAGW, CO  
District File Copy