



**Environmental  
Protection Agency**

Commissioner, Governor  
Lieutenant, Lt. Governor  
Chief, Fisheries Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

September 30, 2010

RE: GEAUGA COUNTY  
PINE LAKE TROUT CLUB  
NON-COMMUNITY, TRANSIENT  
PWS ID # OH2841212

Ms. Patricia Runion  
P.O. Box 23282  
17021 Chillicothe Road  
Chagrin Falls, OH 44022

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During September 2010**

Dear Ms. Runion:

Pine Lake Trout Club is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

PINE LAKE TROUT CLUB  
SEPTEMBER 30, 2010  
PAGE 2

**4. Monitor with at least five (5) routine samples** in the month following (October 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1149.

Sincerely,



Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM/ams

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Geauga County Health Department  
Information Management Section, DDAGW, CO  
District File Copy