

State of Ohio

Nor



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

June 23, 2010

RE: HOLMES COUNTY
BLOOMFIELD WATER COMPANY
COMMUNITY
PWS ID: OH3800812

Mr. Ed L. Ames
1817 State Route 83
P.O. Box 332
Millersburg, OH 44654

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Dear Mr. Ames:

Bloomfield Water Company is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period: May 2010
Required Coliform Monitoring: 1 routine per MN
Sample Results Submitted: Zero

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than one year after learning of the violation:


- Mail or other direct delivery to each customer; OR
 - Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and
 - If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting or Internet posting;
 - Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.
2. **Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

BLOOMFIELD WATER COMPANY
JUNE 23, 2010
PAGE 2

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1114 .

Sincerely,



Anne Karney
Environmental Engineer
Division of Drinking and Ground Waters

AK:ds

enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Holmes County Health Department
Information Management Section, DDAGW, CO