



State of Ohio |

OH3842512 LIGHT IN THE VALLEY CHURCH

21 06/25/10

North



TELE: (330)

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

June 25, 2010

RE: HOLMES COUNTY  
LIGHT IN THE VALLEY CHURCH  
NON-COMMUNITY, TRANSIENT  
PWS ID: OH3842512

**CERTIFIED MAIL**

Mr. Dean Mullet  
4150 TR 162  
Sugarcreek, OH 44681

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During June 2010 (ACUTE)**

Dear Mr. Mullet:

Light in the Valley Church is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. coli* fecal coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

**IMMEDIATE ACTION REQUIRED:**

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the NEDO at 330-963-1202.
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
  - Hand delivery to persons served by the water system
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
  - Send to parents or guardians of children at schools or day care facilities
  - Another delivery method approved in writing by the director
  - Posted notices must remain in place for as long as the violation exists.
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

**NOTE: Issuance of a Public Notice must be repeated every 30 days** for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

LIGHT IN THE VALLEY CHURCH  
JUNE 25, 2010  
PAGE 2

3. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
4. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
5. **Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
6. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact Anne Karney at 330-963-1202.

Sincerely,



Nancy N. Rice  
Environmental Engineer  
Division of Drinking and Ground Waters

NNR:dms

enclosures: Tier 1 Public Notification  
Public Notice Instructions and Verification Form

cc: Holmes County Health Department  
Information Management Section, DDAGW, CO  
Anne Karney, DDAGW, NEDO  
Kim Eppers, DDAGW, NEDO