

**Environmental  
Protection Agency**

Pat. Cleveland, Governor  
Les. Fisher, Lt. Governor  
Dana L. Luteski, Director

OH3850412 MILLERSBURG WEST BELLSTORE PWS

22 10/18/10 A



**NOTICE OF VIOLATION – ACTION REQUIRED**

October 18, 2010

RE: HOLMES COUNTY  
MILLERSBURG WEST BELLSTORE PWS  
NON-COMMUNITY, TRANSIENT  
PWS ID # OH3850412

Mr. Robert D. Engel  
611 Erie Street South  
P.O. Box 907  
Massillon, OH 44648-0907

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During October 2010**

Dear Mr. Engel:

Millersburg West Bellstore PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as “special purpose”).
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

MILLERSBURG WEST BELLSTORE PWS  
OCTOBER 18, 2010  
PAGE 2

- 4. Monitor with at least five (5) routine samples** in the month following (November 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1202.

Sincerely,



Anne Karney  
Environmental Engineer  
Division of Drinking and Ground Waters

AK/ams

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Holmes County Health Department  
Information Management Section, DDAGW, CO