



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH4300903 MADISON VILLAGE PWS

22 07/16/10



NOTICE OF VIOLATION – ACTION REQUIRED

July 19, 2010

**RE: LAKE COUNTY
MADISON VILLAGE PWS
COMMUNITY
PWS ID: OH4300903**

Mr. Matthew Zapp
126 West Main Street
Madison, OH 44057

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During July 2010**

Dear Mr. Zapp:

Madison Village PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Mail or other direct delivery to each customer;
 - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - NEDO.** Include a copy of each notice distributed, published or posted.

MADISON VILLAGE PWS


JULY 19, 2010

PAGE 2

- 4. Monitor with at least five (5) routine samples** in the month following (August 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1199.

Sincerely,

A handwritten signature in black ink that reads "Stephen Bopple". The signature is written in a cursive style with a large, prominent "S" and "B".

Stephen Bopple, P.E.

Environmental Engineer

Division of Drinking and Ground Waters

SB:ds

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Lake County Health Department
Information Management Section, DDAGW, CO
District File Copy