



State of Ohio Environmental Protection Agency
North



TELE: (330) 966-1200 FAX: (330) 967-8700
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

2110 East Aurora Rd.
Twinsburg, Ohio 44087

NOTICE OF VIOLATION – ACTION REQUIRED

January 27, 2010

RE: LORAIN COUNTY
CRYSTAL SPRINGS CAMPGROUND, LIMITED PWS
NON-COMMUNITY, TRANSIENT
PWS ID # OH4731012

Mr. Michael Scaletta
SDC Home and Neighborhoods
36097 Westminister Road
North Ridgeville, OH 44039

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Dear Mr. Scaletta:

Crystal Springs Campground, Limited PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period:	October-December 2009
Required Coliform Monitoring:	1 per Quarter
Sample Results Submitted:	0

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

- 1. Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.


- 2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

DIVISION OF DRINKING AND GROUNDWATER, LIMITED PWS
July 2011
PAGE

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1277.

Sincerely,



Scott D. Moegling
Environmental Engineer
Division of Drinking and Ground Waters

SDM/ams

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Lorain County Health Department
Information Management Section, DDAGW, CO
Herchal Starkey, Crystal Springs Campground