



**Environmental
Protection Agency**

Secretary, Governor
Lieutenant, Lt. Governor
Chief, Administration, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 4, 2010

RE: PORTAGE COUNTY
ELK'S CLUB 1377 PWS
NON-COMMUNITY, TRANSIENT
PWS ID # OH6783612

Mr. Ken Dulaney
P.O. Box 1377
Kent, OH 44240

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2010**

Elk's Club 1377 PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

As stated in a letter sent October 19, 2010, a routine sample was collected from your facility on 9/29/2010 and determined total coliform positive. OAC Rule 3745-81-21 requires four repeat samples to be collected in a timely fashion and on the same day upon notification of the positive routine sample result(s). Elk's Club 1377 PWS did not collect the four required repeat samples and therefore are in violation of the OAC. A public notice water use advisory was required to be issued because of this violation. The public notice for the water use advisory must remain in effect until you obtain one complete set of four repeat samples that are determined total coliform negative.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
 4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
 5. **Monitor with at least five (5) routine samples** in the month following (November 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1182.

Sincerely,



Laurel Hricik
Environmental Specialist
Division of Drinking and Ground Waters

LH/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Portage County Health Department
Information Management Section, DDAGW, CO