



State of Ohio Envir
Northeast



* 0 H 7 6 5 5 5 1 2 4 2 8 3 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 467-0769
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

May 27, 2010

RE: STARK COUNTY
FIRST ENERGY TRAINING CENTER PWS
PWS TYPE: NON-COMMUNITY, TRANSIENT
PWS ID: OH7655512

Mr. Vince Conant
76 S. Main St.
Akron, OH 44308

Subject: Failure to Sample Source Water for Fecal Indicators (Total Coliform) as Required

Dear Mr. Conant:

First Energy Training Center PWS is in violation of Federal Code, Rule 141.402 for failure to comply with the Ground Water Rule monitoring.

Monitoring Period:	May 2010
Required Monitoring:	1 per Month
Sample Results Submitted:	0

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

FIRST ENERGY TRAINING CENTER PWS

MAY 27, 2010

PAGE 2

- 2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

If source water (raw) samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1269.

Sincerely,



Mandy Razzano
Environmental Specialist
Division of Drinking and Ground Waters

MR:ds

enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Stark County Health Department
Information Management Section, DDAGW, CO
Kim Ethers, DDAGW-NEDO