State of Ohio Env
Northe
2110 East Aurora Rd.
Twinsburg, Ohio 44087
TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

OH7657612 NEW BALTIMORE COMMUNITY CHURCH 22 05/20/10 A

OH7657612853501 1

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

May 20, 2010

RE: STARK COUNTY
NEW BALTIMORE COMMUNITY CHURCH
NON-TRANSIENT NON-COMMUNITY
PWS ID: OH7657612

Mr. Colin Pullen
7761 Pontius Street NE
Alliance, OH 44601

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During April-June 2010

Dear Mr. Pullen:

New Baltimore Community Church is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination**. Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").

2. **Notify the people served by this water system**. Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

   - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
   - Mail or other direct delivery to each customer;
   - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
   - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

4. **Monitor with at least five (5) routine samples** in the month following (June 2010) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1236.

Sincerely,

David J. Bowland
Environmental Specialist
Division of Drinking and Ground Waters

DJB:dms

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Stark County Health Department
Information Management Section, DDAGW, CO
District File Copy