



State of Ohio Environ

Northeast



* 0 H 7 6 7 5 5 1 2 2 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 467-0709
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 5, 2010

RE: STARK COUNTY
ROSE HILL WATER COMPANY
COMMUNITY WATER SYSTEM
PWS ID # OH7675512

Mr. Fred Tobin, Owner
Rose Hill Water Company
7694 Strausser Ave., NW
North Canton, OH 44720

Dear Mr. Tobin:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least five appropriate sites for lead and copper analyses during the July - December 2009 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from five appropriate taps for lead and copper during the January - June 2010 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system. An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.
3. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963-1236.

Sincerely,

Dave Bowland
Environmental Specialist
Division of Drinking and Ground Waters

DB/ams

Enclosures: Public Notice, Verification Form

cc: Ohio EPA, Central Office, DDAGW, IMS
Kim Ethers, Ohio EPA, NEDO, DDAGW

