



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korieski, Director

OH7700020 DEVILLE DEVELOPMENTS PWS

51 07/23/10 I



July 26, 2010

RE: SUMMIT COUNTY
DEVILLE DEVELOPMENTS
NTNC WATER SYSTEM
PWS ID#OH7700020

Mr. Robert Brown
R.L. DeVille Enterprises, LTD
3951 Convenience Circle NW
Suite 301
Canton, OH 44718

RE: VIOLATION NOTIFICATION

Dear Mr. Brolin:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least ten appropriate sites for lead and copper analyses during the January – June 2010 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from 10 appropriate taps for lead and copper during the July – December 2010 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system. An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.
3. Issue Consumer Notice of Tap Water Results. The new lead and copper rule became effective July 24, 2009. Any lead monitoring conducted on or after that date require a "Consumer Notice of Tap Water Results" to be issued and a verification form be sent to the Northeast District Office. Please forward an example of a notice and completed verification along with your lead and copper report. Templates can be found on our Web site at: www.epa.ohio.gov/ddagw/reporting.aspx#Forms.

DEVILLE DEVELOPMENTS
JULY 26, 2010
PAGE 2

4. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963-1227.

Sincerely,



Ursula Musselman
Environmental Specialist
Division of Drinking and Ground Waters

UM:ds

enclosures: Public Notice, Verification Form

cc: IMS, DDAGW, CO
Kim Ethers, NEDO, DDAGW