



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korieski, Director

OH7837112 DEER CREEK GOLF COURSE

23 08/24/10 A



NOTICE OF VIOLATION – ACTION REQUIRED

August 24, 2010

**RE: TRUMBULL COUNTY
DEER CREEK GOLF COURSE
NON-COMMUNITY, TRANSIENT
PWS ID: OH7837112**

Mr. James Lacivita
7691 East Liberty St.
Hubbard, OH 44425

Subject: Failure To Sample Drinking Water For Total Coliforms As Required

Dear Mr. Lacivita:

Deer Creek Golf Course is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period: July 2010
Required Coliform Monitoring: 5 routines the month following a routine positive
Sample Results Submitted: 0

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

1. Notify the people served by this water system using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

DEER CREEK GOLF COURSE
AUGUST 24, 2010
PAGE 2

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1242.

Sincerely,

A handwritten signature in black ink that reads "Mandy Romano" followed by a small mark that looks like "64".

Charlotte Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CH:ds

enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Trumbull County Health Department
Information Management Section, DDAGW, CO