



State of Ohio Enviro  
Northeast

OH1504112 GUILFORD HIGHLANDS MOBILE HOME PARK 22 05/27/09



\* 0 H 1 5 0 4 1 1 2 6 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

ed Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

May 27, 2009

RE: COLUMBIANA COUNTY  
GUILFORD HIGHLANDS MOBILE HOME PARK  
COMMUNITY WATER SYSTEM  
PWS ID # OH1504112

Ms. Liz Eshenbaugh  
7716 Depot Rd.  
Lisbon, OH 44432

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During May 2009**

Dear Ms. Eshenbaugh:

Guilford Highlands Mobile Home Park PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**


1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Mail or other direct delivery to each customer;
  - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

GUMMUT, NORTH ANDS BARRETT HILL PARK PWS  
BARRETT HILL PARK  
PABLO

**4. Monitor with at least five (5) routine samples** in the month following (June 2009) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1248.

Sincerely,



J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Columbiana County Health Department  
Information Management Section, DDAGW, CO