



State of Ohio Environm  
Northeast Di



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

June 26, 2009

RE: GEAUGA COUNTY  
GEAUGA PARKS-DONALD MEYER CENTER  
NON-COMMUNITY, TRANSIENT  
PWS ID: OH2855812

Mr. Jerry Holzheimer  
9160 Robinson Rd  
Chardon, OH 44024-9148

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During April-June 2009**

Dear Mr. Holzheimer:

Geauga Parks-Donald Meyer Center is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

GEAUGA PARKS-DONALD MEYER CENTER


JUNE 26, 2009

PAGE 2

**4. Monitor with at least five (5) routine samples** in the month following (July 2009) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1149.

Sincerely,

Handwritten signature of Kathy Metropulos in black ink, featuring a stylized 'K' and 'M'.

Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM/ams

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Geauga County Health Department  
Information Management Section, DDAGW, CO