



State of Ohio Environment  
Northeast District

OH2833012 GRANDVIEW GOLF CLUB

23 07/22/09 A



\* 0 H 2 8 3 3 0 1 2 8 6 4 3 4 1 1 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

July 24, 2009

RE: GEAUGA COUNTY  
**GRANDVIEW GOLF CLUB**  
NON-COMMUNITY, TRANSIENT  
PWS ID: OH2833012

Mr. Steve Johnson  
P.O. Box 361  
Middlefield, OH 44062

**Subject: Failure to Sample Drinking Water for Total Coliforms as Required**

Dear Mr. Johnson:

Grandview Golf Club is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

|                                      |                 |
|--------------------------------------|-----------------|
| <b>Monitoring Period:</b>            | April-June 2009 |
| <b>Required Coliform Monitoring:</b> | 1 per Quarter   |
| <b>Sample Results Submitted:</b>     | 0               |

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

**ACTION REQUIRED:**

- 1. Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

**Timing:** As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

- 2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact me at 330-963-1149.

Sincerely,



Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM:ds

enclosures: Tier 3 Public Notification  
Public Notice Instructions & Verification Form

cc: Geauga County Health Department  
Information Management Section, DDAGW, CO