




State of Ohio Environment  
Northeast District

OH5244912 GIANT OIL #440 PWS

25 07/09/09



\* 0 H 5 2 4 4 9 1 2 7 9 0 3 7 1 0 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

July 9, 2009

RE: MEDINA COUNTY  
GIANT OIL #440 PWS  
NON-COMMUNITY, TRANSIENT  
PWS ID # OH5244912

Mr. Russ Weston  
P.O. Box 30042  
East Canton, OH 44730

**Subject: Failure to Conduct Required Repeat Total Coliform Monitoring**

Dear Mr. Russ Weston:

Giant Oil #440 PWS is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-21 for April-June 2009.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 6/25/2009 and the required repeat samples were not collected. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

**IMMEDIATE ACTION REQUIRED:**

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the Northeast District Office 330-963-1282.
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
  - Hand delivery to persons served by the water system;
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Send to parents or guardians of children at schools or day care facilities;
  - Another delivery method approved in writing by the director;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

**NOTE: Issuance of a Public Notice must be repeated every 30 days** for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.


GIANT OIL #440 PWS  
JULY 9, 2009  
PAGE 2

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples** in the month following (July 2009) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact Donn Meehl at 330-963-1282.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR/ams

Enclosures: Tier 1 Public Notification  
Public Notice Instructions and Verification Form

cc: Medina County Health Department  
Information Management Section, DDAGW, CO  
Kim Etters, DDAGW, NEDO