



State of Ohio Environn
Northeast C



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

ed Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

November 2, 2009

RE: PORTAGE COUNTY
SEBRING COUNTRY CLUB
NON-COMMUNITY, TRANSIENT
PWS ID: OH6753012

Ms. Marilyn Brumbaugh
54 Hartzel Road
North Benton, OH 44449

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2009**

Dear Ms. Brumbaugh:

Sebring Country Club is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). It is noted that Sebring Country Club has closed for the season and will collect 5 routine samples upon opening in April 2009. Ohio EPA records indicate that your public water system is open April 1 through September 30. If this information is incorrect, please contact this office.

If you have any questions, contact me at 330-963-1269.

Sincerely,



Mandy Razzano
Environmental Specialist
Division of Drinking and Ground Waters

MR:ds

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Portage County Health Department
Information Management Section, DDAGW, CO
District File Copy