



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

December 23, 2009

RE: TRUMBULL COUNTY
CONCORD CARE CTR.-HARTFORD
COMMUNITY WATER SYSTEM
PWS ID# OH7800812
LEAD AND COPPER

Ms. Dianne McFarland
Concord Care Center-Hartford
4250 Sodom-Hutchings Road
Cortland, OH 44410

Subject: Notice of Violation of failure to issue public education materials for lead action level exceedance

Dear Ms. McFarland:

A review of our records indicates that your public water system incurred a violation of rule 3745-81-85 of the Ohio Administrative Code (OAC) for failure to distribute lead public education information on lead in drinking water to each person served by the Concord Care Center-Hartford water system by November 29, 2009. The delivery of public education material is required whenever a public water system exceeds the lead action level.

Please note that you are still required to distribute the lead public educational materials within 30 days of receipt of this letter and submit verification of distribution to this office not more than 10 days after distribution. Public education must be distributed every 12 months as long as the water system exceeds the lead action level.

Actions required as a result of the above violation

Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> 1. Mail or other direct delivery to each customer, and 2. Any other method reasonably calculated to reach other persons regularly served by the system.
Step 2	<p>Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Northeast District Office of the Ohio EPA.</p>

CONCORD CARE CENTER-HARTFORD
December 23, 2009
PAGE 2

Step 3	Within 30 days provide the appropriate lead exceedance public education as required by letter dated September 15, 2008.
Step 4	Fill out the attached verification form and send along with a copy of the public education materials issued within 10 days to the Northeast District Office of the Ohio EPA.

If you have any questions, please contact me at (330) 963-1242.

Sincerely,


Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH:dms

enclosures

cc: Kim Ethers, DDAGW, NEDO