



State of Ohio Environ
Northeast I



* 0 H 8 5 4 9 1 1 2 8 7 3 1 3 0 9 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

ted strockman, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 7, 2009

RE: WAYNE COUNTY
AMISH DOOR RESTAURANT
NON-TRANSIENT, NON-COMMUNITY
PUBLIC WATER SYSTEM
PWS ID # OH8549112

Mr. Randy Troyer
Amish Door Restaurant
6655 East Lincoln Way
Wooster, OH 44691

Subject: Notice of Violation of failure to issue public education materials and for lead action level exceedance

Dear Mr. Troyer:

A review of our records indicates that your public water system incurred a violation of rule 3745-81-85 (C)(4) and (C)(5) of the Ohio Administrative Code (OAC) for failure to distribute public education information via pamphlets, brochures, or electronic transmission on lead in drinking water to each person served by the non-transient, non-community water system by November 29, 2008. The delivery of public education material is required whenever a public water system exceeds the lead action level. Please refer to our letter of October 16, 2007, enclosed. Your public water system exceeded the lead action level during the sampling period from June - September 2007.

Please note that you are still required to distribute the lead public educational materials within 30 days of receipt of this letter and submit verification of distribution to this office not more than 10 days after distribution. Public education must be distributed every 12 months as long as the water system exceeds the lead action level.

Actions required as a result of the above violation

Step 1	Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)
Step 2	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Northeast District Office of the Ohio EPA.

AMISH DOOR RESTAURANT
JANUARY 7, 2009
PAGE 2

Step 3	Within 30 days , provide the appropriate lead exceedance public education as required by letter dated October 16, 2007.
Step 4	Fill out the attached verification form and send along with a copy of the public education materials issued within 10 days to the Northeast District Office of the Ohio EPA.

If you have any questions, please contact Beth Madis at (330) 963-1194.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

Enclosures (5)

ec: Beth Madis, Ohio EPA, NEDO, DDAGW
cc: Kim Eters, Ohio EPA, NEDO, DDAGW
Information Management Section, Ohio EPA, Central Office, DDAGW
Ken Baughman, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Rick Jackson, Operator