

State of



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

July 14, 2009

RE: WAYNE COUNTY
CHIPPEWA GOLF CORP
NON-COMMUNITY, TRANSIENT
PWS ID # OH8534012

Mr. Kevin Larizza
12147 Shank Road
Doylestown, OH 44230

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During April-June 2009**

Dear Mr. Larizza:

Chippewa Golf Corp is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:


- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

CHIPPEWA GOLF CORP
JULY 14, 2009
PAGE 2

4. Monitor with at least five (5) routine samples in the month following (July 2009) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1194.

Sincerely,



Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Wayne County Health Department
Information Management Section, DDAGW, CO