



State of Ohio Environ  
Northeast



\* 0 H 1 0 0 0 5 1 2 7 2 5 3 1 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

July 21, 2008

RE: CARROLL COUNTY  
PRIDE VALLEY MHP  
PUBLIC COMMUNITY  
PWS ID # OH1000512

Pride Valley Mobile Home Park  
9147 Maple Street, Lot 7a  
Malvern, OH 44644

**CERTIFIED MAIL**

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During July 2008 (ACUTE)**

Dear Sir or Madam:

Pride Valley MHP is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. coli*/fecal coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

**IMMEDIATE ACTION REQUIRED:**

- 1. Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the Northeast District Office at 330-963-1293.
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.

<b>Public Community</b>
<ul style="list-style-type: none"> <li>• Fax notice to broadcast media (radio and television);</li> <li>• Fax notice to newspaper (to editor, not legal notice section);</li> <li>• Hand delivery;</li> <li>• Contact sensitive populations (hospitals, day care, schools, nursing homes);</li> <li>• Direct telecommunication (if applicable);</li> <li>• If applicable, provide copy to owner/operator of any consecutive water system for distribution to their customers.</li> </ul>
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>

**NOTE: Issuance of a Public Notice must be repeated every 30 days** for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

- 3. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 4. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.
- 5. Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
- 6. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact Cynthia M. Petretich at (330) 963-1293.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR/ams

Enclosures: Tier 1 Public Notification  
Public Notice Instructions and Verification Form

cc: Carroll County Health Department  
Kim Eters, DDAGW, NEDO  
Information Management Section, DDAGW, CO