



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 28, 2008

RE: CARROLL COUNTY
ATWOOD LAKE LODGE (RESORT)
NTNC WATER SYSTEM
PWS ID. NO. 1038311

Mr. Boris Slogar, P.E.
Chief Engineer
Muskingum Watershed Conservancy District
1319 Third Street
P.O. Box 349
New Philadelphia, OH 44663

TREATMENT TECHNIQUE CT VIOLATION

Dear Mr. Slogar:

The Atwood Lake Lodge public water system is in violation of Ohio Revised Code chapter 6109 by failing to comply with the requirements for disinfection of surface water pursuant to Ohio Administrative Code (OAC) rule 3745-81-72.

The Atwood Lake Lodge public water system failed to provide sufficient disinfection treatment of its drinking water on January 3, 4, 5, and 6 when the actual CT value during the maximum hourly flow rate did not meet or exceed the required CT value.

Failure to meet any requirement of OAC 3745-81-72 is a treatment technique violation for which public notification is required. The public notice shall be conducted in accordance with OAC 3745-32 (C) and shall be provided as soon as practical but no later than 30 days after the public water system learns of the violation. Non-community water systems shall provide notice using one or more of the following forms of delivery in order to reach all persons served.

1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than seven days).
2. Public notice issued by direct delivery to each customer and service connection (where known).

ATWOOD LAKE LODGE (RESORT)
FEBRUARY 28, 2008
PAGE 2

If the above methods do not reach all persons served, then use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).

The required public notice is included with this correspondence. Should you wish to make any modifications to it, you must contact this office and receive our approval prior to issuance. A copy of the public notice and the completed verification form must be returned to the Ohio EPA Northeast District Office, 2110 East Aurora Road, Twinsburg, OH 44087 within ten (10) days after issuing the notice.

If you have any questions, please contact me at (330) 963-1173 or email me at dave.maschak@epa.state.oh.us.

Respectfully,



David Maschak
Environmental Specialist
Division of Drinking and Ground Waters

DM:ds

enclosures: Tier 2 SWTR Notice – Disinfection Contact Time (#41)
Verification Form

pc: Kim Eppers, DDAGW, NEDO
Carroll County Health Department
IMS/DDAGW, CO
Kim Rhoads, Legal, CO
Kenneth Baughman, DDAGW-CMCU
James J. Pringle, Attorney-at-Law
Mark Jukich, Manager of Operations-MWCD
Bill Newsome, President, H₂O Technologies
Brian Bisson, Aqua Ohio, Inc.