



State of Ohio Environ
Northeast L



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

July 17, 2008

RE: COLUMBIANA COUNTY
ANDI'S CONVENIENCE STORE
TRANSIENT NON COMMUNITY
PWS ID # OH1534412

Andi's Convenience Store
7517 Depot Road
Rogers, Ohio 44455

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During June 2008 (Monthly)**

Dear Owner/Operator:

Andi's Convenience Store is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

As stated in a letter sent June 30, 2008, a routine sample was collected from your facility on June 26, 2008 and determined total coliform positive. OAC Rule 3745-81-21 requires four repeat samples to be collected in a timely fashion and on the same day upon notification of the positive routine sample result(s). Andi's Convenience Store did not collect the four required repeat samples and therefore are in violation of the OAC. A public notice water use advisory was required to be issued because of this violation. The public notice for the water use advisory must remain in effect until you obtain one complete set of four repeat samples that are determined total coliform negative.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non-Community** column.

Transient or Non-Transient Non-Community
<ul style="list-style-type: none"> • Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; • Mail or other direct delivery to each customer • Send to parents or guardians of children at schools or day care facilities • E-mail, newsletters or newspaper


ANDI'S CONVENIENCE STORE
JULY 17, 2008
PAGE 2

Posted notices must remain in place for **as long as** the violation exists, but in no case for **less** than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make **changes** to the public notice without consulting with **Ohio EPA** beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at (330) 963-1293.

Sincerely,



Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Columbiana County Health Department
Kim Eppers, Ohio EPA, NEDO, DDAGW
Information Management Section, DDAGW, CO