



State of Ohio Environ
Northeast

OH2874612 CLARIDON PLAZA PWS

51 01/25/08



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 25, 2008

RE: GEAUGA COUNTY
CLARIDON PLAZA
NTNC WATER SYSTEM
PWS ID # OH2874612

Mr. Peter Mowad
Empire Real Estate
1042 Main Street
Aliquippia, PA 15001

Dear Mr. Mowad:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least 5 appropriate sites for lead and copper analyses during the July – December 2007 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from 5 appropriate taps for lead and copper during the January – June 2008 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system. An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.
3. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963- 1121.

Sincerely,

Corey Kurjian
Environmental Specialist
Division of Drinking and Ground Waters

Enclosures: Public Notice, Verification Form

cc: Ohio EPA, Central Office, DDAGW-IMS
Kim Etters, NEDO, DDAGW

CK/ams