



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 17, 2008

RE: GEAUGA COUNTY  
THE BELL STATION  
TRANSIENT  
PWS # OH2864312

The Bell Station  
5196 Chillicothe Road  
South Russell, OH 44022

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in January 2008.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| <b>Actions required as a result of the above violation</b> |  |
|--|--|
| Step 1   | <p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2   | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.  |
| Step 3   | Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.   |
| Step 4   | <b>Because you are required to monitor with at least five (5) routine samples in the next month following any total coliform-positive result, you must take at least five (5) routine total coliform samples in February 2008.</b>   |

THE BELL STATION  
JANUARY 17, 2008  
PAGE 2

If you have any questions, please contact me at (330) 963-1282.

Sincerely,

A handwritten signature in cursive script that reads "Donn Meehl".

Donn Meehl  
Environmental Specialist  
Division of Drinking and Ground Waters

DM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Geauga County Health Department  
Kim Eters, Ohio EPA, NEDO, DDAGW