



State of Ohio Environme

Northeast Di:



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

November 17, 2008

RE: GEAUGA COUNTY
MUNSON PLAZA/PETRONZIO MGMT. PWS
TRANSIENT NON COMMUNITY
PWS ID: OH2842312

Petronzio Management Co., LLC
8228 Mayfield Rd, Suite 1-A
Chesterland, OH 44026

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2008**

Munson Plaza/Petronzio Mgmt PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

Transient or Non Transient Non Community	
<ul style="list-style-type: none"> • Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; • Mail or other direct delivery to each customer • Send to parents or guardians of children at schools or day care facilities • E-mail, newsletters or newspaper 	
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.

MUNSON PLAZA/PETRONZIO MGMT. PWS
NOVEMBER 17, 2008
PAGE 2

4. **Monitor with at least five (5) routine samples** in the month following (November 2008) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).
5. Ohio EPA has received the required repeat samples mentioned in the letter dated November 12, 2008. Please ensure that all results are submitted in a timely manner to the Ohio EPA-Northeast District Office. The violation for failure to collect repeat samples has been rescinded.

If you have any questions, contact me at 330-963-1149.

Sincerely,


Kathy Metropulos
Environmental Specialist
Division of Drinking and Ground Waters

KM:ds

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Geauga County Health Department
Northeast District Office Files
Information Management Section, DDAGW, CO