



State of Ohio Environn  
Northeast C



\* 0 H 2 8 5 5 7 1 2 7 2 9 0 4 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

August 08, 2008

RE: GEAUGA COUNTY  
**CENTERVILLE MILLS CONFERENCE  
CENTER PWS**  
TRANSIENT NON COMMUNITY  
PWS ID: OH2855712

Centerville Mills Park  
8558 Crackel Road  
Chagrin Falls, OH 44023

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During July-September Quarter of 2008 (Monthly)**

Centerville Mills Conference Center PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

<b>Transient or Non Transient Non Community</b>	
<ul style="list-style-type: none"> <li>• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;</li> <li>• Mail or other direct delivery to each customer</li> <li>• Send to parents or guardians of children at schools or day care facilities</li> <li>• E-mail, newsletters or newspaper</li> </ul>	
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	


- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - . Include a copy of each notice distributed, published or posted.

CENTERVILLE MILLS CONFERENCE CENTER PWS  
AUGUST 08, 2008  
PAGE 2

- 4. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1149.

Sincerely,



Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM:ds

enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Geauga County Health Department  
Northeast District Office Files  
Kim Ethers, DDAGW, NEDO  
Information Management Section, DDAGW, CO