



State of Ohio Environn  
Northeast D

OH3840612 HOPEWELL PRESBYTERIAN CHURCH

25 01/31/08



\* 0 H 3 8 4 0 6 1 2 8 5 5 3 5 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 31, 2008

RE: HOLMES COUNTY  
**HOPEWELL PRESBYTERIAN CHURCH**  
TRANSIENT PWS  
PWS ID #OH3840612

**CERTIFIED MAIL**

Hopewell Presbyterian Church  
6900 S.R. 754  
Shreve, OH 44676

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)**

During January 2008, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	<p>Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.</p>

HOPEWELL PRESBYTERIAN CHURCH  
JANUARY 31, 2008  
PAGE 2

Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC Rule 3745-81-21 (B)(7).

If you have any questions, please contact Daniel D. Underwood at (330) 963-1113.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Holmes County Health Department  
Kim Ethers, Ohio EPA, NEDO, DDAGW