



State of Ohio Environment
Northeast District

OH3842512 LIGHT IN THE VALLEY CHURCH

22 04/29/08 A



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

April 29, 2008

RE: HOLMES COUNTY
LIGHT IN THE VALLEY CHURCH
TRANSIENT NON COMMUNITY
PWS ID: OH3842512

Light in the Valley Church
4150 TR 162
Sugarcreek, OH 44681

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During April 2008 (Monthly)**

Dear Sir/Madam:

Light in The Valley Church is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. A violation of this rule occurs when more than one of your samples within the month were total coliform-positive.

As stated in a letter sent April 25, 2008, a routine sample was collected from your facility on April 10, 2008 and determined total coliform positive. OAC Rule 3745-81-21 requires four repeat samples to be collected in a timely fashion and on the same day upon notification of the positive routine sample result(s). Light in the Valley Church did not collect the four required repeat samples and therefore are in violation of the OAC. A public notice water use advisory was required to be issued because of this violation. The public notice for the water use advisory must remain in effect until you obtain one complete set of four repeat samples that are determined total coliform negative.

OTHER ACTIONS REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

- Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer
- Send to parents or guardians of children at schools or day care facilities
- E-mail, newsletters or newspaper


Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

LIGHT IN THE VALLEY CHURCH
APRIL 29, 2008
PAGE 2

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B) (7).

If you have any questions, contact me at 330-963-1182.

Sincerely,



Michael W. Scott
Environmental Engineer
Division of Drinking and Ground Waters

MWS:dms

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Holmes County Health Department
Northeast District Office Files
Information Management Section, DDAGW, CO