



State of Ohio Enviro

Northeast

OH6774512 MID-WAY DRIVE-IN THEATER

22 08/08/08 A



\* 0 H 6 7 7 4 5 1 2 8 4 5 9 8 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

August 08, 2008

RE: PORTAGE COUNTY  
**MID-WAY DRIVE IN THEATER PWS**  
TNC WATER SYSTEM  
PWS ID: OH6774512

Mid-Way Drive-In Theater  
1413 Golden Gate Blvd., Suite 205  
Mayfield Hts., OH 44124

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During July-September Quarter of 2008 (Monthly)**

Dear Sir/Madam:

Mid-Way Drive-In Theater PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

<b>Transient or Non Transient Non Community</b>	
<ul style="list-style-type: none"> <li>• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;</li> <li>• Mail or other direct delivery to each customer</li> <li>• Send to parents or guardians of children at schools or day care facilities</li> <li>• E-mail, newsletters or newspaper</li> </ul>	
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - . Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1269.

Sincerely,



Mandy Razzano  
Environmental Specialist  
Division of Drinking and Ground Waters

MR:ds

enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

cc: Geauga County Health Department  
Northeast District Office Files  
Kim Ethers, DDAGW, NEDO  
Information Management Section, DDAGW, CO