



State of Ohio Environme

Northeast Di

OH7638512 MARLBORO MFG INC

22 06/04/08 A



\* 0 H 7 6 3 8 5 1 2 8 2 7 2 8 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**NOTICE OF VIOLATION – ACTION REQUIRED**

June 04, 2008

RE: STARK COUNTY  
**MARLBORO MFG. INC.**  
NON TRANSIENT NON COMMUNITY  
PWS ID: OH7638512

Marlboro Manufacturing, Inc.  
11750 Marlboro Avenue NE  
Alliance, OH 44601

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During June 2008 (Monthly)**

Dear Sir/Madam:

Marlboro Mfg Inc. is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Non Transient Non Community** column.

<b>Public Community</b>	<b>Transient or Non Transient Non Community</b>
<ul style="list-style-type: none"> <li>• Mail or other direct delivery to each customer.</li> <li>• If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting.</li> </ul>	<ul style="list-style-type: none"> <li>• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;</li> <li>• Mail or other direct delivery to each customer</li> <li>• Send to parents or guardians of children at schools or day care facilities.</li> <li>• E-mail, newsletters or newspaper</li> </ul>
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1236.

Sincerely,



Dave Bowland  
Environmental Specialist  
Division of Drinking and Ground Water

DB:ds

enclosures: . Tier 2 Public Notification  
Public Notice Instructions and Verification Form

pc: Stark County Health Department  
Northeast District Office Files  
Information Management Section, DDAGW, CO