



State of Ohio Environm  
Northeast D



\* 0 H 7 6 4 6 5 1 2 9 7 6 6 3 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 19, 2008

RE: STARK COUNTY  
MEADOWLAKE GOLF & SWIM  
TRANSIENT NON-COMMUNITY  
PWS ID # OH7646512

Messrs. Roy E. Barr and Philip Barr  
dba Meadowlake Golf & Swim  
Meadowlake Corporation  
Meadowlake, Limited  
1211 39<sup>th</sup> Street NE  
Canton, OH 44714

**Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.**

Dear Messrs. Barr:

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the month of **APRIL 2008**, because your water system uses a source that has been designated as a surface water source and you do not provide adequate treatment. Although you have made modifications to your water well, you will continue to be in violation of OAC Rule 3745-81-73 until you obtain four consecutive quarters of total coliform negative raw water samples from the farm house well. Only then would Ohio EPA be able to designate your source as ground water.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italics on the attached public notice is mandatory and must be included as written.</i></p>
Step 2	Initiate an Investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

MEADOWLAKE GOLF & SWIM  
MAY 19, 2008  
PAGE 2

Any questions regarding this matter should be directed to the Attorney General's Office through your attorney.

Sincerely,

A handwritten signature in black ink, appearing to read "Nancy N. Rice". The signature is fluid and cursive, with the first name being the most prominent.

Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Stark County Health Department  
Kim Ethers, Ohio EPA, NEDO, DDAGW