Ohio
State of Ohio Environm
Northeast I

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

September 04, 2008

RE: SUMMIT COUNTY
CAMP Y NOAH-LDC PWS
TRANSIENT NON COMMUNITY
PWS ID: OH7727012

Camp Y Noah
815 Mount Pleasant Road
Clinton, OH 44216

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) and Failure to Sample 5 Routine Samples the Month Following a Routine Positive During June and July 2008

Camp Y Noah-LDC PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Camp Y Noah-LDC PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination**. Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").

2. **Notify the people served by this water system**. Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

Transient or Non Transient Non Community
• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; • Mail or other direct delivery to each customer • Send to parents or guardians of children at schools or day care facilities • E-mail, newsletters or newspaper
Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification forms within 10 days of issuing the Public Notices** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

Please be reminded that all future samples submitted to the lab must have the proper PWS ID number associated with that sample.

If you have any questions, contact me at 330-963-1227.

Sincerely,

Ursula Musselman

Ursula Musselman
Environmental Specialist
Division of Drinking and Ground Waters

UM:ds

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Summit County Health Department
Northeast District Office Files
Kim Etters, DDAGW, NEDO
Doug Kohl, President/CEO, Camp Y Noah
Information Management Section, DDAGW, CO