



* 0 H 8 5 0 2 8 1 2 8 7 2 6 3 0 8 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087TELE: (330) 963-1200 FAX: (330) 467-0700
www.epa.state.oh.usLee Fisher, Lieutenant Governor
Chris Korleski, Director

September 15, 2008

RE: WAYNE COUNTY
PEACH GROVE MOBILE HOME PARK
2227 BLACHLEYVILLE RD., WOOSTER
COMMUNITY WATER SYSTEM
PWS ID # OH8502812
STU ID # 8559609Marianne Warren
5704 Sunland St. NE
Louisville, OH 44641**SUBJECT: CCR VIOLATIONS**

Dear Ms. Warren:

Ohio EPA has reviewed the 2007 Consumer Confidence Report (CCR) for the Peach Grove Mobile Home Park PWS on September 12, 2008. The CCR was reviewed for the required content. Based on our review, the Peach Grove Mobile Home Park public water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements, the following violations were noted:

1. The Table of Detected Contaminants was missing some information. You must list contaminants detected in your drinking water for the subject year, or the last time a contaminant was tested (since not all contaminants are sampled for annually). Of specific concern is nitrate, which has been detected yearly, at relatively high levels. Other omissions and errors were included in the table and in the report.
2. Monitoring or reporting violation information was not included in the report. During 2007, you were issued two monitoring or reporting violations.
3. Required health language due to an exceedance of a level of concern was not included for Nitrate. Nitrate was detected in your water at levels between 2.8 and 9 mg/L. Although the maximum contaminant level of 10 mg/L was not exceeded, the level of concern, 5 mg/L, was exceeded, and therefore the following language is needed:

Section 11: {Include this paragraph if the nitrate level is greater than 5.0 ppm but less than 10 ppm} Nitrate in drinking water at levels above 10 ppm is a health risk for infants less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

PEACH GROVE MOBILE HOME PARK
SEPTEMBER 15, 2008
PAGE 2

This language can be found in the CCR template instructions located at our Web site at <http://www.epa.state.oh.us/ddagw/Documents/ccrtemplate08.pdf>.

4. Your verification form indicates that you mailed a copy of your CCR to postal patrons in your service area. However, the form does not show that you delivered a copy to each water customer, nor the date of delivery.

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Northeast District Office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BM/ams

cc: Wayne County Health Department
Ohio EPA, Central Office, DDAGW/IMS
Kim Etters, Ohio EPA, NEDO, DDAGW