

State of Ohio

North



* 0 H 8 5 6 4 1 1 2 2 0 8 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 24, 2008

RE: WAYNE COUNTY
BOVILLE INDUSTRIAL COATINGS
NTNC WATER SYSTEM
PWS ID # OH8564112

Mr. Larry Boville
Boville Industrial Coatings
P.O. Box 187
Smithville, OH 44677

Dear Mr. Boville:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least 5 appropriate sites for lead and copper analyses during the July--December 2007 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from 5 appropriate taps for lead and copper during the January--June 2008 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system. An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.
3. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963-1194.

Sincerely,


Beth Madis, Environmental Specialist
Division of Drinking and Ground Waters

BM/ams

Enclosures: Public Notice, Verification Form

cc: Ohio EPA, Central Office, DDAGW -- IMS
Kim Etters, NEDO, DDAGW